Report Date:
21-Jul-08 12:12

☑ Final Report
☐ Re-Issued Report
☐ Revised Report

SPECTRUM ANALYTICAL, INC.
Featuring
HANIBAL TECHNOLOGY

Laboratory Report

Poughkeepsie Water Treatment Facility
3431 North Road
Poughkeepsie, NY 12601
Attn: Matthew Geho

Project: PWTF - Poughkeepsie, NY
Project Annual SOC Analysis

Laboratory ID	Client Sample ID	Matrix	Date Sampled	Date Received
SA80603-01	Plant Effluent 81107	Drinking Water	25-Jun-08 08:00	25-Jun-08 16:50

I attest that the information contained within the report has been reviewed for accuracy and checked against the quality control requirements for each method. These results relate only to the sample(s) as received.
All applicable NELAC requirements have been met.
Please note that this report contains 6 pages of analytical data plus Chain of Custody document(s).
This report may not be reproduced, except in full, without written approval from Spectrum Analytical, Inc.

Massachusetts Certification # M-MA138/MA1110
Connecticut # PH-0777
Florida # E87600/E87936
Maine # MA138
New Hampshire # 2538
New Jersey # MA011/MA012
New York # 11393/11840
Rhode Island # 98
USDA # S-51435
Vermont # VT-11393

Authorized by:

Hanibal C. Tayeh, Ph.D.
President/Laboratory Director

Technical Reviewer's Initial:

Spectrum Analytical, Inc. is a NELAC accredited laboratory organization and meets NELAC testing standards. Use of the NELAC logo however does not insure that Spectrum is currently accredited for the specific method or analyte indicated. Please refer to our "Quality" web page at www.spectrum-analytical.com for a full listing of our current certifications and fields of accreditation. States in which Spectrum Analytical, Inc. holds NELAC certification are New York, New Hampshire, New Jersey and Florida. All analytical work for Volatile Organic and Air analysis are transferred to and conducted at our 830 Silver Street location (NY-11840, FL-E87936 and NJ-MA012).

Sample Identification	Client Project #	Matrix	Collection Date/Time	Received
Plant Effluent 81107 SA80603-01	Annual SOC Analysis	Drinking Water	25-Jun-08 08:00	25-Jun-08

CAS No.	*Analyte(s)*	*Result*	*Flag*	*Units*	**RDL*	*MDL*	*Dilution*	*Method Ref.*	*Prepared*	*Analyzed*	*Batch*	*Analyst*
Volatile Organic Compounds												
524.2 Purgeable Organic Compounds												
Prepared by method SW846 5030 Water MS												
76-13-1	1,1,2-Trichlorotrifluoroethane (Fre 113)	BRL	U	µg/l	0.5	0.4	1	EPA 524.2	01-Jul-08	01-Jul-08	8070046	ek
67-64-1	Acetone	BRL	U	µg/l	10.0	0.8	1	"	"	"	"	"
107-13-1	Acrylonitrile	BRL	U	µg/l	0.5	0.3	1	"	"	"	"	"
71-43-2	Benzene	BRL	U	µg/l	0.5	0.2	1	"	"	"	"	"
108-86-1	Bromobenzene	BRL	U	µg/l	0.5	0.3	1	"	"	"	"	"
74-97-5	Bromochloromethane	BRL	U	µg/l	0.5	0.2	1	"	"	"	"	"
75-27-4	Bromodichloromethane	9.7		µg/l	0.5	0.3	1	"	"	"	"	"
75-25-2	Bromoform	BRL	U	µg/l	0.5	0.4	1	"	"	"	"	"
74-83-9	Bromomethane	BRL	U	µg/l	0.5	0.3	1	"	"	"	"	"
78-93-3	2-Butanone (MEK)	BRL	U	µg/l	10.0	0.4	1	"	"	"	"	"
104-51-8	n-Butylbenzene	BRL	U	µg/l	0.5	0.3	1	"	"	"	"	"
135-98-8	sec-Butylbenzene	BRL	U	µg/l	0.5	0.3	1	"	"	"	"	"
98-06-6	tert-Butylbenzene	BRL	U	µg/l	0.5	0.2	1	"	"	"	"	"
75-15-0	Carbon disulfide	BRL	U	µg/l	0.5	0.4	1	"	"	"	"	"
56-23-5	Carbon tetrachloride	BRL	U	µg/l	0.5	0.5	1	"	"	"	"	"
108-90-7	Chlorobenzene	BRL	U	µg/l	0.5	0.2	1	"	"	"	"	"
75-00-3	Chloroethane	BRL	U	µg/l	0.5	0.3	1	"	"	"	"	"
67-66-3	Chloroform	21.5		µg/l	0.5	0.3	1	"	"	"	"	"
74-87-3	Chloromethane	BRL	U	µg/l	0.5	0.2	1	"	"	"	"	"
95-49-8	2-Chlorotoluene	BRL	U	µg/l	0.5	0.2	1	"	"	"	"	"
106-43-4	4-Chlorotoluene	BRL	U	µg/l	0.5	0.3	1	"	"	"	"	"
96-12-8	1,2-Dibromo-3-chloropropane	BRL	U	µg/l	0.5	0.3	1	"	"	"	"	"
124-48-1	Dibromochloromethane	2.3		µg/l	0.5	0.3	1	"	"	"	"	"
106-93-4	1,2-Dibromoethane (EDB)	BRL	U	µg/l	0.5	0.2	1	"	"	"	"	"
74-95-3	Dibromomethane	BRL	U	µg/l	0.5	0.2	1	"	"	"	"	"
95-50-1	1,2-Dichlorobenzene	BRL	U	µg/l	0.5	0.2	1	"	"	"	"	"
541-73-1	1,3-Dichlorobenzene	BRL	U	µg/l	0.5	0.2	1	"	"	"	"	"
106-46-7	1,4-Dichlorobenzene	BRL	U	µg/l	0.5	0.3	1	"	"	"	"	"
75-71-8	Dichlorodifluoromethane (Freon12	BRL	U	µg/l	0.5	0.5	1	"	"	"	"	"
75-34-3	1,1-Dichloroethane	BRL	U	µg/l	0.5	0.2	1	"	"	"	"	"
107-06-2	1,2-Dichloroethane	BRL	U	µg/l	0.5	0.2	1	"	"	"	"	"
75-35-4	1,1-Dichloroethene	BRL	U	µg/l	0.5	0.5	1	"	"	"	"	"
156-59-2	cis-1,2-Dichloroethene	BRL	U	µg/l	0.5	0.2	1	"	"	"	"	"
156-60-5	trans-1,2-Dichloroethene	BRL	U	µg/l	0.5	0.2	1	"	"	"	"	"
78-87-5	1,2-Dichloropropane	BRL	U	µg/l	0.5	0.2	1	"	"	"	"	"
142-28-9	1,3-Dichloropropane	BRL	U	µg/l	0.5	0.3	1	"	"	"	"	"
594-20-7	2,2-Dichloropropane	BRL	U	µg/l	0.5	0.3	1	"	"	"	"	"
563-58-6	1,1-Dichloropropene	BRL	U	µg/l	0.5	0.4	1	"	"	"	"	"
10061-01-5	cis-1,3-Dichloropropene	BRL	U	µg/l	0.5	0.2	1	"	"	"	"	"
10061-02-6	trans-1,3-Dichloropropene	BRL	U	µg/l	0.5	0.2	1	"	"	"	"	"
100-41-4	Ethylbenzene	BRL	U	µg/l	0.5	0.2	1	"	"	"	"	"
87-68-3	Hexachlorobutadiene	BRL	U	µg/l	0.5	0.4	1	"	"	"	"	"
591-78-6	2-Hexanone (MBK)	BRL	U	µg/l	10.0	0.3	1	"	"	"	"	"
98-82-8	Isopropylbenzene	BRL	U	µg/l	0.5	0.3	1	"	"	"	"	"
99-87-6	4-Isopropyltoluene	BRL	U	µg/l	0.5	0.3	1	"	"	"	"	"
1634-04-4	Methyl tert-butyl ether	BRL	U	µg/l	0.5	0.2	1	"	"	"	"	"
108-10-1	4-Methyl-2-pentanone (MIBK)	BRL	U	µg/l	10.0	0.2	1	"	"	"	"	"
75-09-2	Methylene chloride	BRL	U	µg/l	0.5	0.4	1	"	"	"	"	"
91-20-3	Naphthalene	BRL	U	µg/l	0.5	0.2	1	"	"	"	"	"
103-65-1	n-Propylbenzene	BRL	U	µg/l	0.5	0.3	1	"	"	"	"	"

Sample Identification	Client Project #	Matrix	Collection Date/Time	Received
Plant Effluent 81107 SA80603-01	Annual SOC Analysis	Drinking Water	25-Jun-08 08:00	25-Jun-08

CAS No.	Analyte(s)	Result	Flag	Units	*RDL	MDL	Dilution	Method Ref.	Prepared	Analyzed	Batch	Analyst
Volatile Organic Compounds												
524.2 Purgeable Organic Compounds												
Prepared by method SW846 5030 Water MS												
100-42-5	Styrene	BRL	U	µg/l	0.5	0.2	1	EPA 524.2	01-Jul-08	01-Jul-08	8070046	ek
630-20-6	1,1,1,2-Tetrachloroethane	BRL	U	µg/l	0.5	0.3	1	"	"	"	"	"
79-34-5	1,1,2,2-Tetrachloroethane	BRL	U	µg/l	0.5	0.2	1	"	"	"	"	"
127-18-4	Tetrachloroethene	BRL	U	µg/l	0.5	0.4	1	"	"	"	"	"
108-88-3	Toluene	BRL	U	µg/l	0.5	0.3	1	"	"	"	"	"
87-61-6	1,2,3-Trichlorobenzene	BRL	U	µg/l	0.5	0.2	1	"	"	"	"	"
120-82-1	1,2,4-Trichlorobenzene	BRL	U	µg/l	0.5	0.2	1	"	"	"	"	"
71-55-6	1,1,1-Trichloroethane	BRL	U	µg/l	0.5	0.4	1	"	"	"	"	"
79-00-5	1,1,2-Trichloroethane	BRL	U	µg/l	0.5	0.3	1	"	"	"	"	"
79-01-6	Trichloroethene	BRL	U	µg/l	0.5	0.2	1	"	"	"	"	"
75-69-4	Trichlorofluoromethane (Freon 11	BRL	U	µg/l	0.5	0.4	1	"	"	"	"	"
96-18-4	1,2,3-Trichloropropane	BRL	U	µg/l	0.5	0.3	1	"	"	"	"	"
95-63-6	1,2,4-Trimethylbenzene	BRL	U	µg/l	0.5	0.2	1	"	"	"	"	"
108-67-8	1,3,5-Trimethylbenzene	BRL	U	µg/l	0.5	0.2	1	"	"	"	"	"
75-01-4	Vinyl chloride	BRL	U	µg/l	0.5	0.5	1	"	"	"	"	"
179601-23-1	m,p-Xylene	BRL	U	µg/l	0.5	0.5	1	"	"	"	"	"
95-47-6	o-Xylene	BRL	U	µg/l	0.5	0.2	1	"	"	"	"	"
109-99-9	Tetrahydrofuran	BRL	U	µg/l	10.0	0.5	1	"	"	"	"	"
994-05-8	Tert-amyl methyl ether	BRL	U	µg/l	0.5	0.3	1	"	"	"	"	"
637-92-3	Ethyl tert-butyl ether	BRL	U	µg/l	0.5	0.2	1	"	"	"	"	"
108-20-3	Di-isopropyl ether	BRL	U	µg/l	0.5	0.2	1	"	"	"	"	"
75-65-0	Tert-Butanol / butyl alcohol	BRL	U	µg/l	10.0	3.0	1	"	"	"	"	"
Surrogate recoveries:												
460-00-4	*4-Bromofluorobenzene*	*96*		*80-120 %*				"	"	"	"	"
2037-26-5	*Toluene-d8*	*103*		*80-120 %*				"	"	"	"	"
17060-07-0	*1,2-Dichloroethane-d4*	*111*		*80-120 %*				"	"	"	"	"
1868-53-7	*Dibromofluoromethane*	*111*		*80-120 %*				"	"	"	"	"
Microextractable Organic Compounds												
106-93-4	1,2-Dibromoethane (EDB)	BRL	U	µg/l	0.0100	0.00980	1	EPA 504.1	02-Jul-08	03-Jul-08	8070132	SM
Subcontracted Analyses												
Subcontracted Analyses												
Prepared by method E508.1												
15972-60-8	Alachlor	BRL		mg/L	0.00019	0.000028	1	EPA508.1	02-Jul-08 09:45	03-Jul-07 01:26	54040	ELAB
1912-24-9	Atrazine	BRL		mg/L	0.000095	).000006	1	"	"	"	"	"
57-74-9	Chlordane	BRL		mg/L	0.00019	0.000018	1	"	"	"	"	"
72-20-8	Endrin	BRL		mg/L	0.0000095	).000001	1	"	"	"	"	"
58-89-9	gamma-BHC	BRL		mg/L	0.000019	).000001	1	"	"	"	"	"
76-44-8	Heptachlor	BRL		mg/L	0.000038	).000005	1	"	"	"	"	"
1024-57-3	Heptachlor epoxide	BRL		mg/L	0.000019	.0000009	1	"	"	"	"	"
118-74-1	Hexachlorobenzene	BRL		mg/L	0.000095	1	1	"	"	"	"	"
77-47-4	Hexachlorocyclopentadiene	BRL		mg/L	0.000095	0.000013	1	"	"	"	"	"
72-43-5	Methoxychlor	BRL		mg/L	0.000095	0.000013	1	"	"	"	"	"
12674-11-2	PCB 1016	BRL		mg/L	0.000095	).000006	1	"	"	"	"	"
11104-28-2	PCB 1221	BRL		mg/L	0.000095	0.000013	1	"	"	"	"	"
11141-16-5	PCB 1232	BRL		mg/L	0.000095	0.000011	1	"	"	"	"	"
53469-21-9	PCB 1242	BRL		mg/L	0.000095	0.000014	1	"	"	"	"	"
12672-29-6	PCB 1248	BRL		mg/L	0.000095	0.000029	1	"	"	"	"	"
11097-69-1	PCB 1254	BRL		mg/L	0.000095	).000006	1	"	"	"	"	"
11096-82-5	PCB 1260	BRL		mg/L	0.000095	).000006	1	"	"	"	"	"

This laboratory report is not valid without an authorized signature on the cover page.

* Reportable Detection Limit BRL = Below Reporting Limit

Sample Identification	Client Project #	Matrix	Collection Date/Time	Received
Plant Effluent 81107 SA80603-01	Annual SOC Analysis	Drinking Water	25-Jun-08 08:00	25-Jun-08

CAS No.	Analyte(s)	Result	Flag	Units	*RDL	MDL	Dilution	Method Ref.	Prepared	Analyzed	Batch	Analyst
Subcontracted Analyses												
Subcontracted Analyses												
Prepared by method E508.1												
122-34-9	Simazine	BRL		mg/L	0.000066	0.000018	1	EPA508.1	02-Jul-08 09:45	03-Jul-07 01:26	54040	ELAB
	Total PCBs	BRL		mg/L	0.000095	0.000095	1	"	"	"	"	"
8001-35-2	Toxaphene	BRL		mg/L	0.00095	0.00022	1	"	"	"	"	"
Surrogate recoveries:												
2051-24-3	*Decachlorobiphenyl*	*102*		*70-130 %*				"	"	"	"	"
Subcontracted Analyses												
Prepared by method E515.3												
93-72-1	2,4,5-TP (Silvex)	BRL		mg/L	0.0002	0.000038	1	EPA515.3	01-Jul-08 09:00	02-Jul-08 15:39	54012	"
94-75-7	2,4-D	BRL		mg/L	0.0001	0.000054	1	"	"	"	"	"
75-99-0	Dalapon	BRL		mg/L	0.001	0.0006	1	"	"	"	"	"
1918-00-9	Dicamba	BRL		mg/L	0.0001	0.000059	1	"	"	"	"	"
88-85-7	Dinoseb	BRL		mg/L	0.0002	0.000096	1	"	"	"	"	"
87-86-5	Pentachlorophenol	BRL		mg/L	0.00004	0.000004	1	"	"	"	"	"
1918-02-1	Picloram	BRL		mg/L	0.0001	0.000037	1	"	"	"	"	"
Surrogate recoveries:												
19719-28-9	*DCAA*	*111.07*		*70-130 %*				"	"	"	"	"
Subcontracted Analyses												
Prepared by method E525.2												
309-00-2	Aldrin	BRL		mg/L	0.000096	0.000048	1	EPA525.2	01-Jul-08 16:00	11-Jul-08 07:47	54015	"
50-32-8	Benzo(a)pyrene	BRL		mg/L	0.000096	0.000035	1	"	"	"	"	"
23184-66-9	Butachlor	BRL		mg/L	0.000096	0.000042	1	"	"	"	"	"
103-23-1	Di(2-ethylhexyl)adipate	BRL		mg/L	0.0015	0.00022	1	"	"	"	"	"
117-81-7	Di(2-ethylhexyl)phthalate	0.001	Q1	mg/L	0.0019	0.00048	1	"	"	"	"	"
60-57-1	Dieldrin	BRL		mg/L	0.00013	0.000024	1	"	"	"	"	"
51218-45-2	Metolachlor	BRL		mg/L	0.00096	0.000041	1	"	"	"	"	"
21087-64-9	Metribuzin	BRL		mg/L	0.00029	0.000054	1	"	"	"	"	"
1918-16-7	Propachlor	BRL		mg/L	0.00019	0.000023	1	"	"	"	"	"
Surrogate recoveries:												
81-20-9	*1,3-Dimethyl-2-nitrobenzene*	*97.8*		*70-130 %*				"	"	"	"	"
1520-96-3	*Perylene-d12*	*110.6*		*70-130 %*				"	"	"	"	"
	Triphenylphosphate	*124.4*		*70-130 %*				"	"	"	"	"
Subcontracted Analyses												
Prepared by method												
16655-82-6	3-Hydroxycarbofuran	BRL		mg/L	0.002	0.00021	1	EPA531.1	09-Jul-08 16:00	10-Jul-08 14:59	R69815	"
116-06-3	Aldicarb	BRL		mg/L	0.002	0.00018	1	"	"	"	"	"
1646-88-4	Aldicarb sulfone	BRL		mg/L	0.002	0.00022	1	"	"	"	"	"
1646-87-3	Aldicarb sulfoxide	BRL		mg/L	0.002	0.00013	1	"	"	"	"	"
63-25-2	Carbaryl	BRL		mg/L	0.002	0.00014	1	"	"	"	"	"
1563-66-2	Carbofuran	BRL		mg/L	0.002	0.00013	1	"	"	"	"	"
2032-65-7	Methiocarb	BRL		mg/L	0.002	0.00013	1	"	"	"	"	"
16752-77-5	Methomyl	BRL		mg/L	0.002	0.00018	1	"	"	"	"	"
23135-22-0	Oxamyl	BRL		mg/L	0.002	0.00016	1	"	"	"	"	"
Surrogate recoveries:												
114-26-1	*Propoxur*	*117.02*		*80-120 %*				"	"	"	"	"
1071-83-6	Glyphosate	BRL		mg/L	0.006	0.00099	1	EPA547	08-Jul-08 16:00	09-Jul-08 16:54	R69770	"
145-73-3	Endothall	BRL		mg/L	0.009	0.00028	1	EPA548.1	02-Jul-08 09:00	08-Jul-08 19:24	54039	"

This laboratory report is not valid without an authorized signature on the cover page.

* Reportable Detection Limit BRL = Below Reporting Limit

Sample Identification	Client Project #	Matrix	Collection Date/Time	Received
Plant Effluent 81107 SA80603-01	Annual SOC Analysis	Drinking Water	25-Jun-08 08:00	25-Jun-08

CAS No.	*Analyte(s)*	*Result*	*Flag*	*Units*	**RDL*	*MDL*	*Dilution*	*Method Ref.*	*Prepared*	*Analyzed*	*Batch*	*Analyst*
Subcontracted Analyses												
85-00-7	Diquat	BRL		mg/L	0.0004	0.00021	1	EPA549.2	02-Jul-08 15:05	02-Jul-08 20:40	54041	ELAB

Notes and Definitions

Q1	Analyte detected below quatitations limits.
U	Analyte included in the analysis, but not detected
BRL	Below Reporting Limit - Analyte NOT DETECTED at or above the reporting limit
dry	Sample results reported on a dry weight basis
NR	Not Reported
RPD	Relative Percent Difference

A plus sign (+) in the Method Reference column indicates the method is not accredited by NELAC.

Laboratory Control Sample (LCS): A known matrix spiked with compound(s) representative of the target analytes, which is used to document laboratory performance.

Matrix Duplicate: An intra-laboratory split sample which is used to document the precision of a method in a given sample matrix.

Matrix Spike: An aliquot of a sample spiked with a known concentration of target analyte(s). The spiking occurs prior to sample preparation and analysis. A matrix spike is used to document the bias of a method in a given sample matrix.

Method Blank: An analyte-free matrix to which all reagents are added in the same volumes or proportions as used in sample processing. The method blank should be carried through the complete sample preparation and analytical procedure. The method blank is used to document contamination resulting from the analytical process.

Method Detection Limit (MDL): The minimum concentration of a substance that can be measured and reported with 99% confidence that the analyte concentration is greater than zero and is determined from analysis of a sample in a given matrix type containing the analyte.

Reportable Detection Limit (RDL): The lowest concentration that can be reliably achieved within specified limits of precision and accuracy during routine laboratory operating conditions. For many analytes the RDL analyte concentration is selected as the lowest non-zero standard in the calibration curve. While the RDL is approximately 5 to 10 times the MDL, the RDL for each sample takes into account the sample volume/weight, extract/digestate volume, cleanup procedures and, if applicable, dry weight correction. Sample RDLs are highly matrix-dependent.

Surrogate: An organic compound which is similar to the target analyte(s) in chemical composition and behavior in the analytical process, but which is not normally found in environmental samples. These compounds are spiked into all blanks, standards, and samples prior to analysis. Percent recoveries are calculated for each surrogate.

Validated by:
Hanibal C. Tayeh, Ph.D.

✓SA801603 Ck

SPECTRUM ANALYTICAL, INC.
Featuring
HANIBAL TECHNOLOGY

CHAIN OF CUSTODY RECORD

Page _____ of _____

Special Handling:
- ☒ Standard TAT - 7 to 10 business days
- ☐ Rush TAT - Date Needed: _____
- All TATs subject to laboratory approval. Min. 24-hour notification needed for rushes.
- Samples disposed of after 60 days unless otherwise instructed.

Report To: PWTF
3431 North Road.
Poughkeepsie, NY 12601

Project Mgr.: Matthew Geho

Invoice To: Matthew Geho

P.O. No.: _____ RQN: _____

Project No.: Annual SOC Analysis
Site Name: P.W.T.F.
Location: Poughkeepsie State: NY
Sampler(s): M. Geho

1=$Na_2S_2O_3$ 2=HCl 3=H_2SO_4 4=HNO_3 5=NaOH 6=Ascorbic Acid
7=CH_3OH 8=$NaHSO_4$ 9=$Na_2S_2O_3$ & MCAA 10=Sodium Sulfite & HCL

DW=Drinking Water GW=Groundwater WW=Wastewater
O=Oil SW=Surface Water SO=Soil SL=Sludge A=Air
X1=_____ X2=_____ X3=_____

G=Grab C=Composite

QA Reporting Notes: (check if needed)
- ☐ Provide MA DEP MCP CAM Report
- ☐ Provide CT DEP RCP Report

QA/QC Reporting Level
☐ Standard ☐ No QC
☐ Other _____

State specific reporting standards: _____

Lab Id:	Sample Id:	Date:	Time:	Type	Matrix	Preservative	# of VOA Vials	# of Amber Glass	# of Clear Glass	# of Plastic	EPA 525	EPA 568	EPA 515	EPA 549 Digest	EPA 548	EPA 531.1	EPA 547	EPA 504	EPA 524.2
SA801603 01	Plant Effluent 81107	6/25/08	08:00	G	DW	10		1			X								
	Plant Effluent 81107	6/25/08	08:00	G	DW	10		1				X							
	Plant Effluent 81107	6/25/08	08:00	G	DW	1		1					X						
	Plant Effluent 81107	6/25/08	08:00	G	DW	3				1				X					
	Plant Effluent 81107	6/25/08	08:00	G	DW	1		1							X				
	Plant Effluent 81107	6/25/08	08:00	G	DW	9	2									X			
	Plant Effluent 81107	6/25/08	8:00	G	DW	1	2										X		
	Plant Effluent 81107	6/25/08	8:00	G	DW	1	2											X	
	Plant Effluent 81107	6/25/08	8:00	G	DW	2	2												X

☐ Fax results when available to (____) _____
☐ E-mail to _____
EDD Format _____

Condition upon receipt: ☐ Iced ☐ Ambient ☐ °C (10)

Relinquished by:	Received by:	Date:	Time:
[signature]	[signature]	6/25/08	1115
	[signature]	6/25/08	1630