Report Date:
14-Jul-09 15:31

☑ Final Report
☐ Re-Issued Report
☐ Revised Report

SPECTRUM ANALYTICAL, INC.
Featuring
HANIBAL TECHNOLOGY

Laboratory Report

Poughkeepsie Water Treatment Facility
3431 North Road
Poughkeepsie, NY 12601
Attn: Matthew Geho

Project: PWTF - 3431 North Road, NY
Project Annual Plant Effluent SOC & VOC

Laboratory ID	Client Sample ID	Matrix	Date Sampled	Date Received
SA96795-01	Plant Effluent	Drinking Water	24-Jun-09 08:19	24-Jun-09 20:00

I attest that the information contained within the report has been reviewed for accuracy and checked against the quality control requirements for each method. These results relate only to the sample(s) as received.
All applicable NELAC requirements have been met.

Massachusetts # M-MA138/MA1110
Connecticut # PH-0777
Florida # E87600/E87936
Maine # MA138
New Hampshire # 2538
New Jersey # MA011/MA012
New York # 11393/11840
Pennsylvania # 68-04426/68-02924
Rhode Island # 98
USDA # S-51435
Vermont # VT-11393

Authorized by:

Hanibal C. Tayeh, Ph.D.
President/Laboratory Director

Technical Reviewer's Initial:

Spectrum Analytical holds certification in the State of New York for the analytes as indicated with an X in the "Cert." column within this report. Please note that the State of New York does not offer certification for all analytes.
Please note that this report contains 7 pages of analytical data plus Chain of Custody document(s). When the Laboratory Report is indicated as revised, this report supercedes any previously dated reports for the laboratory ID(s) referenced above. Where this report identifies subcontracted analyses, copies of the subcontractor's test report is available upon request. This report may not be reproduced, except in full, without written approval from Spectrum Analytical, Inc.

Spectrum Analytical, Inc. is a NELAC accredited laboratory organization and meets NELAC testing standards. Use of the NELAC logo however does not insure that Spectrum is currently accredited for the specific method or analyte indicated. Please refer to our "Quality" web page at www.spectrum-analytical.com for a full listing of our current certifications and fields of accreditation. States in which Spectrum Analytical, Inc. holds NELAC certification are New York, New Hampshire, New Jersey and Florida. All analytical work for Volatile Organic and Air analysis are transferred to and conducted at our 830 Silver Street location (NY-11840, FL-E87936 and NJ-MA012).

Please contact the Laboratory or Technical Director at 800-789-9115 with any questions regarding the data contained in this laboratory report.

CASE NARRATIVE:

The sample temperature upon receipt by Spectrum Analytical courier was recorded as 4.8 degrees Celsius. The condition of these samples was further noted as received on ice. The samples were transported on ice to the laboratory facility and the temperature was recorded at 3.0 degrees Celsius upon receipt at the laboratory. Please refer to the Chain of Custody for details specific to sample receipt times.

An infrared thermometer with a tolerance of +/- 2.0 degrees Celsius was used immediately upon receipt of the samples.

If a Matrix Spike (MS), Matrix Spike Duplicate (MSD) or Duplicate (DUP) was not requested on the Chain of Custody, method criteria may have been fulfilled with a source sample not of this Sample Delivery Group.

Sample Identification	Client Project #	Matrix	Collection Date/Time	Received
Plant Effluent SA96795-01	Annual Plant Effluent SOC & VOC	Drinking Water	24-Jun-09 08:19	24-Jun-09

CAS No.	Analyte(s)	Result	Flag	Units	*RDL	Dilution	Method Ref.	Prepared	Analyzed	Batch	Cert.
Volatile Organic Compounds											
524.2 Purgeable Organic Compounds											
Prepared by method SW846 5030 Water MS											
76-13-1	1,1,2-Trichlorotrifluoroethane (Freon 113)	BRL	U	µg/l	0.5	1	EPA 524.2	01-Jul-09	02-Jul-09	9070040	
67-64-1	Acetone	1.8	J	µg/l	10.0	1	"	"	"	"	
107-13-1	Acrylonitrile	BRL	U	µg/l	0.5	1	"	"	"	"	
71-43-2	Benzene	BRL	U	µg/l	0.5	1	"	"	"	"	X
108-86-1	Bromobenzene	BRL	U	µg/l	0.5	1	"	"	"	"	X
74-97-5	Bromochloromethane	BRL	U	µg/l	0.5	1	"	"	"	"	X
75-27-4	Bromodichloromethane	7.0		µg/l	0.5	1	"	"	"	"	X
75-25-2	Bromoform	BRL	U	µg/l	0.5	1	"	"	"	"	X
74-83-9	Bromomethane	BRL	U	µg/l	0.5	1	"	"	"	"	X
78-93-3	2-Butanone (MEK)	BRL	U	µg/l	10.0	1	"	"	"	"	
104-51-8	n-Butylbenzene	BRL	U	µg/l	0.5	1	"	"	"	"	X
135-98-8	sec-Butylbenzene	BRL	U	µg/l	0.5	1	"	"	"	"	X
98-06-6	tert-Butylbenzene	BRL	U	µg/l	0.5	1	"	"	"	"	X
75-15-0	Carbon disulfide	BRL	U	µg/l	0.5	1	"	"	"	"	
56-23-5	Carbon tetrachloride	BRL	U	µg/l	0.5	1	"	"	"	"	X
108-90-7	Chlorobenzene	BRL	U	µg/l	0.5	1	"	"	"	"	X
75-00-3	Chloroethane	BRL	U	µg/l	0.5	1	"	"	"	"	X
67-66-3	Chloroform	21.2		µg/l	0.5	1	"	"	"	"	X
74-87-3	Chloromethane	0.3	J	µg/l	0.5	1	"	"	"	"	X
95-49-8	2-Chlorotoluene	BRL	U	µg/l	0.5	1	"	"	"	"	X
106-43-4	4-Chlorotoluene	BRL	U	µg/l	0.5	1	"	"	"	"	X
96-12-8	1,2-Dibromo-3-chloropropane	BRL	U	µg/l	0.5	1	"	"	"	"	
124-48-1	Dibromochloromethane	1.4		µg/l	0.5	1	"	"	"	"	X
106-93-4	1,2-Dibromoethane (EDB)	BRL	U	µg/l	0.5	1	"	"	"	"	
74-95-3	Dibromomethane	BRL	U	µg/l	0.5	1	"	"	"	"	X
95-50-1	1,2-Dichlorobenzene	BRL	U	µg/l	0.5	1	"	"	"	"	X
541-73-1	1,3-Dichlorobenzene	BRL	U	µg/l	0.5	1	"	"	"	"	X
106-46-7	1,4-Dichlorobenzene	BRL	U	µg/l	0.5	1	"	"	"	"	X
75-71-8	Dichlorodifluoromethane (Freon12)	BRL	U	µg/l	0.5	1	"	"	"	"	X
75-34-3	1,1-Dichloroethane	BRL	U	µg/l	0.5	1	"	"	"	"	X
107-06-2	1,2-Dichloroethane	BRL	U	µg/l	0.5	1	"	"	"	"	X
75-35-4	1,1-Dichloroethene	BRL	U	µg/l	0.5	1	"	"	"	"	X
156-59-2	cis-1,2-Dichloroethene	BRL	U	µg/l	0.5	1	"	"	"	"	X
156-60-5	trans-1,2-Dichloroethene	BRL	U	µg/l	0.5	1	"	"	"	"	X
78-87-5	1,2-Dichloropropane	BRL	U	µg/l	0.5	1	"	"	"	"	X
142-28-9	1,3-Dichloropropane	BRL	U	µg/l	0.5	1	"	"	"	"	X
594-20-7	2,2-Dichloropropane	BRL	U	µg/l	0.5	1	"	"	"	"	X
563-58-6	1,1-Dichloropropene	BRL	U	µg/l	0.5	1	"	"	"	"	X
10061-01-5	cis-1,3-Dichloropropene	BRL	U	µg/l	0.5	1	"	"	"	"	X
10061-02-6	trans-1,3-Dichloropropene	BRL	U	µg/l	0.5	1	"	"	"	"	X
100-41-4	Ethylbenzene	BRL	U	µg/l	0.5	1	"	"	"	"	X
87-68-3	Hexachlorobutadiene	BRL	U	µg/l	0.5	1	"	"	"	"	X
591-78-6	2-Hexanone (MBK)	BRL	U	µg/l	10.0	1	"	"	"	"	
98-82-8	Isopropylbenzene	BRL	U	µg/l	0.5	1	"	"	"	"	X
99-87-6	4-Isopropyltoluene	BRL	U	µg/l	0.5	1	"	"	"	"	X
1634-04-4	Methyl tert-butyl ether	BRL	U	µg/l	0.5	1	"	"	"	"	X
108-10-1	4-Methyl-2-pentanone (MIBK)	BRL	U	µg/l	10.0	1	"	"	"	"	
75-09-2	Methylene chloride	BRL	U	µg/l	0.5	1	"	"	"	"	X
91-20-3	Naphthalene	BRL	U	µg/l	0.5	1	"	"	"	"	

Sample Identification	Client Project #	Matrix	Collection Date/Time	Received
Plant Effluent SA96795-01	Annual Plant Effluent SOC & VOC	Drinking Water	24-Jun-09 08:19	24-Jun-09

CAS No.	Analyte(s)	Result	Flag	Units	*RDL	Dilution	Method Ref.	Prepared	Analyzed	Batch	Cert.
Volatile Organic Compounds											
524.2 Purgeable Organic Compounds											
Prepared by method SW846 5030 Water MS											
103-65-1	n-Propylbenzene	BRL	U	µg/l	0.5	1	EPA 524.2	01-Jul-09	02-Jul-09	9070040	X
100-42-5	Styrene	BRL	U	µg/l	0.5	1	"	"	"	"	X
630-20-6	1,1,1,2-Tetrachloroethane	BRL	U	µg/l	0.5	1	"	"	"	"	X
79-34-5	1,1,2,2-Tetrachloroethane	BRL	U	µg/l	0.5	1	"	"	"	"	X
127-18-4	Tetrachloroethene	BRL	U	µg/l	0.5	1	"	"	"	"	X
108-88-3	Toluene	BRL	U	µg/l	0.5	1	"	"	"	"	X
87-61-6	1,2,3-Trichlorobenzene	BRL	U	µg/l	0.5	1	"	"	"	"	X
120-82-1	1,2,4-Trichlorobenzene	BRL	U	µg/l	0.5	1	"	"	"	"	X
71-55-6	1,1,1-Trichloroethane	BRL	U	µg/l	0.5	1	"	"	"	"	X
79-00-5	1,1,2-Trichloroethane	BRL	U	µg/l	0.5	1	"	"	"	"	X
79-01-6	Trichloroethene	BRL	U	µg/l	0.5	1	"	"	"	"	X
75-69-4	Trichlorofluoromethane (Freon 11)	BRL	U	µg/l	0.5	1	"	"	"	"	X
96-18-4	1,2,3-Trichloropropane	BRL	U	µg/l	0.5	1	"	"	"	"	X
95-63-6	1,2,4-Trimethylbenzene	BRL	U	µg/l	0.5	1	"	"	"	"	X
108-67-8	1,3,5-Trimethylbenzene	BRL	U	µg/l	0.5	1	"	"	"	"	X
75-01-4	Vinyl chloride	BRL	U	µg/l	0.5	1	"	"	"	"	X
179601-23-1	m,p-Xylene	BRL	U	µg/l	0.5	1	"	"	"	"	X
95-47-6	o-Xylene	BRL	U	µg/l	0.5	1	"	"	"	"	X
109-99-9	Tetrahydrofuran	BRL	U	µg/l	10.0	1	"	"	"	"	
994-05-8	Tert-amyl methyl ether	BRL	U	µg/l	0.5	1	"	"	"	"	X
637-92-3	Ethyl tert-butyl ether	BRL	U	µg/l	0.5	1	"	"	"	"	X
108-20-3	Di-isopropyl ether	BRL	U	µg/l	0.5	1	"	"	"	"	X
75-65-0	Tert-Butanol / butyl alcohol	BRL	U	µg/l	10.0	1	"	"	"	"	X
Surrogate recoveries:											
460-00-4	*4-Bromofluorobenzene*	*95*		*80-120 %*			"	"	"	"	
2037-26-5	*Toluene-d8*	*99*		*80-120 %*			"	"	"	"	
17060-07-0	*1,2-Dichloroethane-d4*	*103*		*80-120 %*			"	"	"	"	
1868-53-7	*Dibromofluoromethane*	*101*		*80-120 %*			"	"	"	"	
Microextractable Organic Compounds											
Microextractables by EPA 504.1											
Prepared by method General Preparation SVOC											
96-12-8	1,2-Dibromo-3-chloropropane	BRL	U	µg/l	0.0100	1	EPA 504.1	25-Jun-09	25-Jun-09	9061862	X
106-93-4	1,2-Dibromoethane (EDB)	BRL	U	µg/l	0.0100	1	"	"	"	"	X
Subcontracted Analysis											
Subcontracted Analysis											
Prepared by method EPA 508.1											
Analysis performed by Pace Analytical - 11608											
15972-60-8	Alachlor	BRL		mg/L	0.0002	1	EPA 508.1	02-Jul-09 10:50	08-Jul-09 20:55	62758	
309-00-2	Aldrin	BRL		mg/L	0.000098	1	"	"	"	"	
1912-24-9	Atrazine	BRL		mg/L	0.000098	1	"	"	"	"	
57-74-9	Chlordane	BRL		mg/L	0.0002	1	"	"	"	"	
60-57-1	Dieldrin	BRL		mg/L	0.000098	1	"	"	"	"	
72-20-8	Endrin	BRL		mg/L	0.0000098	1	"	"	"	"	
58-89-9	gamma-BHC	BRL		mg/L	0.00002	1	"	"	"	"	
76-44-8	Heptachlor	BRL		mg/L	0.000039	1	"	"	"	"	
1024-57-3	Heptachlor epoxide	BRL		mg/L	0.00002	1	"	"	"	"	
118-74-1	Hexachlorobenzene	BRL		mg/L	0.000098	1	"	"	"	"	
77-47-4	Hexachlorocyclopentadiene	BRL		mg/L	0.000098	1	"	"	"	"	

This laboratory report is not valid without an authorized signature on the cover page.

* Reportable Detection Limit BRL = Below Reporting Limit

Sample Identification	Client Project #	Matrix	Collection Date/Time	Received
Plant Effluent SA96795-01	Annual Plant Effluent SOC & VOC	Drinking Water	24-Jun-09 08:19	24-Jun-09

CAS No.	Analyte(s)	Result	Flag	Units	*RDL	Dilution	Method Ref.	Prepared	Analyzed	Batch	Cert.
Subcontracted Analysis											
Subcontracted Analysis											
Prepared by method EPA 508.1											
Analysis performed by Pace Analytical - 11608											
72-43-5	Methoxychlor	BRL		mg/L	0.000098	1	EPA 508.1	02-Jul-09 10:50	08-Jul-09 20:55	62758	
12674-11-2	PCB 1016	BRL		mg/L	0.000098	1	"	"	"	"	
11104-28-2	PCB 1221	BRL		mg/L	0.000098	1	"	"	"	"	
11141-16-5	PCB 1232	BRL		mg/L	0.000098	1	"	"	"	"	
53469-21-9	PCB 1242	BRL		mg/L	0.000098	1	"	"	"	"	
12672-29-6	PCB 1248	BRL		mg/L	0.000098	1	"	"	"	"	
11097-69-1	PCB 1254	BRL		mg/L	0.000098	1	"	"	"	"	
11096-82-5	PCB 1260	BRL		mg/L	0.000098	1	"	"	"	"	
122-34-9	Simazine	BRL		mg/L	0.000069	1	"	"	"	"	
	Total PCBs	BRL		mg/L	0.000098	1	"	"	"	"	
8001-35-2	Toxaphene	BRL		mg/L	0.00098	1	"	"	"	"	
Surrogate recoveries:											
2051-24-3	*Decachlorobiphenyl*	*99.6*		*70-130 %*			"	"	"	"	
Subcontracted Analysis											
Prepared by method EPA 515.3											
Analysis performed by Pace Analytical - 11608											
93-72-1	2,4,5-TP (Silvex)	BRL		mg/L	0.0002	1	EPA 515.3	30-Jun-09 11:00	08-Jul-09 01:38	62680	
94-75-7	2,4-D	BRL		mg/L	0.0001	1	"	"	"	"	
75-99-0	Dalapon	BRL		mg/L	0.001	1	"	"	"	"	
1918-00-9	Dicamba	BRL		mg/L	0.0001	1	"	"	"	"	
88-85-7	Dinoseb	BRL		mg/L	0.0002	1	"	"	"	"	
87-86-5	Pentachlorophenol	BRL		mg/L	0.00004	1	"	"	"	"	
1918-02-1	Picloram	BRL		mg/L	0.0001	1	"	"	"	"	
Surrogate recoveries:											
19719-28-9	*DCAA*	*77.74*		*70-130 %*			"	"	"	"	
Subcontracted Analysis											
Prepared by method EPA 525.2											
Analysis performed by Pace Analytical - 11608											
309-00-2	Aldrin	BRL		mg/L	0.000097	1	EPA 525.2	01-Jul-09 10:00	06-Jul-09 20:57	62720	
50-32-8	Benzo(a)pyrene	BRL		mg/L	0.000097	1	"	"	"	"	
23184-66-9	Butachlor	BRL		mg/L	0.000097	1	"	"	"	"	
103-23-1	Di(2-ethylhexyl)adipate	BRL		mg/L	0.0015	1	"	"	"	"	
117-81-7	Di(2-ethylhexyl)phthalate	BRL		mg/L	0.0019	1	"	"	"	"	
60-57-1	Dieldrin	BRL		mg/L	0.00013	1	"	"	"	"	
51218-45-2	Metolachlor	BRL		mg/L	0.00097	1	"	"	"	"	
21087-64-9	Metribuzin	BRL		mg/L	0.00029	1	"	"	"	"	
1918-16-7	Propachlor	BRL		mg/L	0.00019	1	"	"	"	"	
Surrogate recoveries:											
81-20-9	*1,3-Dimethyl-2-nitrobenzene*	*107.8*		*70-130 %*			"	"	"	"	
1520-96-3	*Perylene-d12*	*98.2*		*70-130 %*			"	"	"	"	
	Triphenylphosphate	*110.4*		*70-130 %*			"	"	"	"	
Subcontracted Analysis											
Analysis performed by Pace Analytical - 11608											
16655-82-6	3-Hydroxycarbofuran	BRL		mg/L	0.002	1	EPA 531.1	30-Jun-09 15:00	02-Jul-09 23:49	R80416	

This laboratory report is not valid without an authorized signature on the cover page.

* Reportable Detection Limit BRL = Below Reporting Limit

Sample Identification	Client Project #	Matrix	Collection Date/Time	Received
Plant Effluent SA96795-01	Annual Plant Effluent SOC & VOC	Drinking Water	24-Jun-09 08:19	24-Jun-09

CAS No.	Analyte(s)	Result	Flag	Units	*RDL	Dilution	Method Ref.	Prepared	Analyzed	Batch	Cert.
Subcontracted Analysis											
Subcontracted Analysis											
Analysis performed by Pace Analytical - 11608											
116-06-3	Aldicarb	BRL		mg/L	0.002	1	EPA 531.1	30-Jun-09 15:00	02-Jul-09 23:49	R80416	
1646-88-4	Aldicarb sulfone	BRL		mg/L	0.002	1	"	"	"	"	
1646-87-3	Aldicarb sulfoxide	BRL		mg/L	0.002	1	"	"	"	"	
63-25-2	Carbaryl	BRL		mg/L	0.002	1	"	"	"	"	
1563-66-2	Carbofuran	BRL		mg/L	0.002	1	"	"	"	"	
2032-65-7	Methiocarb	BRL		mg/L	0.002	1	"	"	"	"	
16752-77-5	Methomyl	BRL		mg/L	0.002	1	"	"	"	"	
23135-22-0	Oxamyl	BRL		mg/L	0.002	1	"	"	"	"	
Surrogate recoveries:											
114-26-1	*Propoxur*	*107.33*		*80-120 %*			"	"	"	"	
Analysis performed by Pace Analytical - 11608											
1071-83-6	Glyphosate	BRL		mg/L	0.006	1	EPA 547	09-Jul-09 17:00	09-Jul-09 22:55	R80556	
Analysis performed by Pace Analytical - 11608											
145-73-3	Endothall	BRL		mg/L	0.009	1	EPA 548.1	29-Jun-09 09:00	02-Jul-09 07:25	62646	
Analysis performed by Pace Analytical - 11608											
85-00-7	Diquat	BRL		mg/L	0.0004	1	EPA 549.2	29-Jun-09 14:45	30-Jun-09 17:08	62640	

Notes and Definitions

J	Detected above the Method Detection Limit but below the Reporting Limit; therefore, result is an estimated concentration (CLP J-Flag).
JS	[Undefined]
S	Spike Recovery outside accepted recovery limits
U	Analyte included in the analysis, but not detected
BRL	Below Reporting Limit - Analyte NOT DETECTED at or above the reporting limit
dry	Sample results reported on a dry weight basis
NR	Not Reported
RPD	Relative Percent Difference

A plus sign (+) in the Method Reference column indicates the method is not accredited by NELAC.

Laboratory Control Sample (LCS): A known matrix spiked with compound(s) representative of the target analytes, which is used to document laboratory performance.

Matrix Duplicate: An intra-laboratory split sample which is used to document the precision of a method in a given sample matrix.

Matrix Spike: An aliquot of a sample spiked with a known concentration of target analyte(s). The spiking occurs prior to sample preparation and analysis. A matrix spike is used to document the bias of a method in a given sample matrix.

Method Blank: An analyte-free matrix to which all reagents are added in the same volumes or proportions as used in sample processing. The method blank should be carried through the complete sample preparation and analytical procedure. The method blank is used to document contamination resulting from the analytical process.

Method Detection Limit (MDL): The minimum concentration of a substance that can be measured and reported with 99% confidence that the analyte concentration is greater than zero and is determined from analysis of a sample in a given matrix type containing the analyte.

Reportable Detection Limit (RDL): The lowest concentration that can be reliably achieved within specified limits of precision and accuracy during routine laboratory operating conditions. For many analytes the RDL analyte concentration is selected as the lowest non-zero standard in the calibration curve. While the RDL is approximately 5 to 10 times the MDL, the RDL for each sample takes into account the sample volume/weight, extract/digestate volume, cleanup procedures and, if applicable, dry weight correction. Sample RDLs are highly matrix-dependent.

Surrogate: An organic compound which is similar to the target analyte(s) in chemical composition and behavior in the analytical process, but which is not normally found in environmental samples. These compounds are spiked into all blanks, standards, and samples prior to analysis. Percent recoveries are calculated for each surrogate.

Validated by:
Hanibal C. Tayeh, Ph.D.
Nicole Leja

STA 96795

SPECTRUM ANALYTICAL, INC.
Featuring
HANIBAL TECHNOLOGY

CHAIN OF CUSTODY RECORD

Page ____ of ____

Special Handling:
☐ Standard TAT - 7 to 10 business days
☐ Rush TAT - Date Needed: _____
· All TATs subject to laboratory approval. Min. 24-hour notification needed for rushes.
· Samples disposed of after 60 days unless otherwise instructed.

Report To: PWTF
3431 North Road
Poughkeepsie NY 12601

Project Mgr.: Matthew Geho
Telephone #: 845-451-4173

Invoice To: PWTF

P.O. No.: _____ RQN: _____

Project No.: Annual Plant Effluent SOC & VOC
Site Name: PWTF
Location: Poughkeepsie State: NY
Sampler(s): M. Geho

1=Na_2S2O_3 2=HCl 3=H_2SO_4 4=HNO_3 5=NaOH 6=Ascorbic Acid 7=CH_3OH
8= $NaHSO_4$ 9= $Na_2S_2O_3$ + MCAA 10= Sodium Sulfite + HCl 11= Sulfite

List preservative code below: 2 | 10 | 10 | 11 | 3 | 11 | 9 | 1 | 1

DW=Drinking Water GW=Groundwater WW=Wastewater
O=Oil SW= Surface Water SO=Soil SL=Sludge A=Air
X1=_____ X2=_____ X3=_____

G=Grab C=Composite

QA/QC Reporting Notes: (check as needed)
☐ Provide MA DEP MCP CAM Report
☐ Provide CT DPH RCP Report
QA/QC Reporting Level
☐ Standard ☐ No QC
☐ Other _____
State specific reporting standards: _____

Lab Id:	Sample Id:	Date:	Time:	Type	Matrix	# of VOA Vials	# of Amber Glass	# of Clear Glass	# of Plastic	524.2	EPA 525	EPA 508.1	EPA 515	EPA 549 Diquat	EPA 548	EPA 531.1	EPA 547	EPA 504
96795-01	Plant Effluent	6-24-09	0815 hr	G	DW	2				X								
	Plant Effluent	6-24-09	0815 hr	G	DW		1				X							
	Plant Effluent	6-24-09	0816 hr	G	DW		1					X						
	Plant Effluent	6-24-09	0816 hr	G	DW		1						X					
	Plant Effluent	6-24-09	0817 hr	G	DW				1					X				
	Plant Effluent	6-24-09	0817 hr	G	DW		1								X			
	Plant Effluent	6-24-09	0818 hr	G	DW	2										X		
	Plant Effluent	6-24-09	0818 hr	G	DW	2											X	
	Plant Effluent	6-24-09	0819 hr	G	DW	2												X

EDD Format _____
☐ E-mail to _____

Condition upon receipt: ☐ Iced ☐ Ambient ☐ °C 4.8

Relinquished by:	Received by:	Date:	Time:
Dorothy DeWhite	[signature]	6/24/09	1245
(3) [signature]	[signature]	6/25/09	858